

TEST CERTIFICATE

Certificate No : MCL / 0612101G
Customer Name : شركة بايب استيم
Consultant : ECG
Project : مشروع ابراج العلمين
Sample Description : 1" Thread steel elbow fitting sample
Sample Diameter : 1"
Trade Mark : THAILAND - Tm
Test Description : Hydrostatic test up to 25 bar
Test Duration : Two hour
Received Date : 02/03/2021
Date of Test : 03/03/2021

Test Result :-

The thread steel elbow fitting sample withstand hydrostatic pressure up to 25 bar for two hour without observing any leakage or cracks from the sample body.


N.B.

- These results are only applicable for the sample supplied to the lab.

Validity:

This certificate is valid for one year under normal operating conditions.

Tested By


Mr. Osama Shaaban


Lab Supervisor

Reviewed by


Eng. Sally Hammam

Technical Manager

Approved by


Dr. Prof. T. W. Abou Arab
MCL Director

Issue Date: 04/03/2021