


TEST CERTIFICATE

Certificate No : MCL / 3441901G
Customer Name : شركة بايب استيم
Sample Description : 3/4" Thread steel elbow fitting sample
Sample Diameter : 3/4"
Trade Mark : THAILAND AS Trade mark
Test Description : Hydrostatic test up to 30 bar
Test Duration : one hour
Received Date : 10/12/2019
Date of Test : 11/12/2019



Test Result :-

The thread steel elbow fitting sample withstand hydrostatic pressure up to 30 bar for one hour without observing any leakage or cracks from the sample body.


N.B.

- These results are only applicable for the sample supplied to the lab.

Validity:

This certificate is valid for one year under normal operating conditions.


Tested By



Mr. Osama Shaaban

Lab Supervisor


Reviewed by



Eng. Sally Hammam


Technical Manager

Approved by



Dr. Prof. T. W. Abou Arab

MCL Director



Issue Date: 12/12/2019